

Assessing the value of forecast-based dispatch in the operation of off-grid rural microgrids

S. Mazzola; C.R. Vergara Ramírez; M. Astolfi; V. Li; J.I. Pérez Arriaga;
E. Macchi

Abstract-

Hybrid microgrids are expected to play an important role in the expansion of access to electricity in developing countries. While most of these systems are operated with dispatch strategies which do not make use of predictions about the load or about the availability of renewable energy resources, forecast-based strategies have recently gained attention as an alternative to bring down operation costs. In this work, we develop a framework to assess this potential under a range of assumptions about the quality of load and photovoltaic generation forecasts. The application of the methodology to a village of 600 households reveals cost savings ranging between 2% and 7% depending on the forecast quality and the composition of the microgrid. We also show that sizing microgrid components under the assumption of a predictive operation strategy results in a design with a higher share of intermittent generation.

Index Terms- Microgrid; Rural electrification; Predictive dispatch; Forecasting; Energy management system

Due to copyright restriction we cannot distribute this content on the web. However, clicking on the next link, authors will be able to distribute to you the full version of the paper:

[Request full paper to the authors](#)

If your institution has an electronic subscription to Renewable Energy, you can download the paper from the journal website:

[Access to the Journal website](#)

Citation:

Mazzola, S.; Vergara Ramírez, C.R.; Astolfi, M.; Li, V.; Pérez-Arriaga, I.J.; Macchi, E. "Assessing the value of forecast-based dispatch in the operation of off-grid rural microgrids", Assessing the value of forecast-based dispatch in the operation of off-grid rural microgrids, vol.108, pp.116-125, August, 2017.