

A new methodology of fault location for predictive maintenance of transmission lines

P. Renatha N. da Silva, M. Negrão, P. Júnior, M.A. Sanz-Bobi

Abstract— This paper presents a new methodology for monitoring, in real-time, the conditions of the insulation of an power transmission line, detecting and locating anomalies in its operation, before the supply of power is interrupted, thus allowing for preventive maintenance. This method uses the harmonic decomposition of the leakage current to analyze the condition of line insulation and employs a neural network to locate the fault. Experimental measurements were obtained to validate the simulated results.

Index Terms— Fault location, harmonic decomposition, leakage current, transmission line, artificial neural networks

Due to copyright restriction we cannot distribute this content on the web. However, clicking on the next link, authors will be able to distribute to you the full version of the paper:

[Request full paper to the authors](#)

If you institution has a electronic subscription to International Journal of Electrical Power & Energy Systems, you can download the paper from the journal website:

[Access to the Journal website](#)

Citation:

Renatha N. da Silva, P.; Negrão, M.; Júnior, P.; Sanz-Bobi, M.A.; "A new methodology of fault location for predictive maintenance of transmission lines", International Journal of Electrical Power & Energy Systems, vol.42, no.1, pp.568-574. November, 2012.