

Theoretical and experimental limitations of RoCoF estimation: A geometric approach

J. Gutiérrez-Florensa^{a,*}, F. Sanniti^b, D. Tedeschi^c, L. Sigrist^d, Á. Ortega^d, F. Milano^a

^a School of Electrical & Electronic Engineering, University College Dublin, Dublin, Ireland

^b Department of Industrial Engineering, University of Padova, Italy

^c Terna S.p.A., Roma, Italy

^d Institute for Research in Technology, ICAI, Comillas Pontifical University, Madrid, Spain

ARTICLE INFO

Keywords:

Differential geometry
Fluid mechanics
RoCoF measurement
Signal processing
Under-frequency load shedding

ABSTRACT

A precise estimation of the Rate of Change of Frequency (RoCoF) is crucial for secure power system operation. In fact, RoCoF is strictly related to the amount of the available physical and/or virtual inertia of the system and the severity of the active power unbalance following a disturbance. For this reason, it is widely exploited in different protection systems, e.g., Anti-Islanding, Under Frequency Load Shedding (UFLS) and wide-area protection systems. The new paradigm of modern power systems, with a low-inertia and converter-based generation assets, is increasing the transient severity, making the frequency and the RoCoF estimation more complex and less precise for the actual devices. This work addresses this issue by proposing a numerically robust approach based on concepts inherited from differential geometry and fluid mechanics. The proposed approach is then tested with high-sampling real experimental measurements and used to develop a faster control logic for a RoCoF-based UFLS control scheme. The proposed approach provides information to protections regarding the nature of the contingency which can be used to improve its response.

1. Introduction

1.1. Motivation

RoCoF is formally defined as the time derivative of the instantaneous frequency, i.e. the second time derivative of the phase angle of a voltage signal [1].

In practical applications, it is computed starting from the estimation of the instantaneous frequency, typically provided by a Phase-Locked Loop (PLL) or from the fundamental frequency estimated by a Phasor Measurement Unit (PMU). Then, the time derivative is computed with the adoption of some filtering and its value is averaged on a rolling time window for a smoother behavior [2]. In addition, for protection schemes, an intentional time delay between the detection and actuation can be used to avoid undesirable trips.

Extended rolling windows are typically adopted to improve the RoCoF estimation by reducing noise, unbalances and distortion, at the expense of the promptness of the relay. On the other hand, a shorter time window improves the responsiveness, but oscillations in the RoCoF estimation, for instance, can lead to undesirable trips.

A recent interpretation of the frequency in the framework of the differential geometry (see [3]) creates the conditions to approach the

actual RoCoF computation issues from a novel perspective. In particular, contributions in [4] are especially relevant as they define Quasi Steady-State (QSS) frequency - a novel quantity that captures the slowly-varying fundamental value of frequency - and the time derivative of circulation - a metric that evaluates the physical existence of such frequency. Together, these concepts are here exploited to assess the theoretical and experimental limitations of RoCoF and introduce a novel approach for its estimation.

1.2. Literature review

Nowadays, the problem of the RoCoF estimation in power system applications is still an open challenge. Low-inertia systems exhibit higher values of RoCoF during transients and, at the same time, its estimation is harder due to the higher distortion of the electrical quantities [5].

At present, there is no standard approach to compute RoCoF in power systems. Several techniques have been proposed in the last years [6], which can be grouped in two main categories depending on how the frequency is computed: (i) based on instantaneous frequency measurement (provided, e.g., by a PLL or a Finite Impulse Response (FIR) filter [7]), and (ii) based on fundamental frequency measurement (exploiting, e.g., recursive Discrete Fourier Transform (DFT) techniques [8,9]).

* Corresponding author.

E-mail address: joan.gutierrezflorensa1@ucdconnect.ie (J. Gutiérrez-Florensa).

As the PLL-based estimation is sensitive to amplitude steps, noise and harmonics, typically the formal estimation of RoCoF is filtered and then averaged on a rolling time window, introducing latency in the estimation [10].

DFT-based techniques can be faster since they elaborate on a phasor measurement, even if they require by definition a given time window for the estimation [9]. These methods are also less sensitive to noise and harmonics but their precision deteriorates especially in the first instant after a disturbance, where the signal distortion is higher [11]. Hence, also in this case a proper averaging window has to be selected, vanishing the promptness of the algorithm [12].

In recent literature, PMU-based techniques for RoCoF estimation have arisen among the others, because of their fast reporting rates and responsiveness, and the wide monitoring ability of the PMU architecture [13]. PMU-based RoCoF estimation techniques do not employ averaging to limit the uncertainty given by noise, distortion, and unbalances. As a consequence, the IEEE has significantly relaxed the RoCoF error requirement from 0.01 Hz/s to 0.4 Hz/s [14]. In practice, this level of uncertainty make the RoCoF estimation useless for typical applications, since values close to 1 Hz/s can already be considered critical for the stability of the system [15]. Several synchrophasor-based algorithms have been compared in [13] and [12], where it becomes evident that PMUs provide optimal performance in presence of low fluctuations, as typical of inter-area oscillations, but their measurement is hampered during fast transient events.

The deployment of RoCoF-based relays is mainly focused on three applications: (i) island detection for distribution networks [16], (ii) protection from Loss of Mains (LoM) of embedded generators [17] and (iii) RoCoF-based UFLS schemes, as part of the power system defense plan of many Transmission System Operators (TSOs) [18]. RoCoF-based UFLS schemes allow improving their responsiveness by anticipating the decision to shed load [19,20]. The latter application has gained attention in recent years due to the increased penetration of Inverter-Based Resources (IBRs), which is worsening the effects of power disturbances on frequency stability, as recent blackout events have proven [21,22].

Among several possible topologies of UFLS schemes [23], traditionally based on frequency measurements, semi-adaptive UFLS schemes introduce RoCoF thresholds to trigger the relays in addition to frequency thresholds. For UFLS application, larger absolute RoCoFs values can lead to the following major issues sorted by criticality:

- Frequency collapse before the relays have time to trip;
- Unintentional tripping due to inaccuracy in the measurement of the frequency and/or RoCoF;
- Over extensive Load Shedding (LS) (due to the time delay of activation of the relays).

A trade-off should be found between the promptness of the intervention and the prevention of unintentional trips. In practical applications, often large time windows are chosen, ranging from 500 to 1000 ms [24]. ENTSO-E, e.g., recommends 500 ms as a rolling time window for adequate RoCoF monitoring [2] and recommends also a maximum disconnection time delay [18]. However, to date, recommended criteria for a suitable definition of threshold values and tripping logic are still missing for RoCoF-based UFLS.

1.3. Contributions

Based on a recent development proposed in [4], the paper further elaborates on the definition of RoCoF by means of QSS frequency and utilizes a metric, namely the time derivative of the circulation, able to determine what parts of the voltage trajectory following a power system transient retain the meaning of a slowly-varying fundamental frequency.

Specific contributions of this work are as follows.

- Derive an expression for the RoCoF based on the derivation of QSS frequency;

- Validate the proposed expression by means of high-sampling real-world data provided by the Italian TSO;
- Discuss the impact of the proposed RoCoF estimation on the tripping logic of a semi-adaptive UFLS scheme.

1.4. Paper organization

This paper is structured as follows. Section 2 recalls relevant concepts for the development of the paper and introduces a novel approach for RoCoF estimation. Section 3 assess a real-world case scenario to validate the findings in the previous section. Section 4 evaluates the potential application of the presented theory in UFLS protections through a specific case study. Section 5 provides final remarks and discusses practical considerations. Finally, Section 6 summarizes the main findings and conclusions of the paper.

2. Background and QSS-based RoCoF definition

Based on recent works (see [3,4,25]), we adopt the differential geometry framework to define electrical quantities in direct analogy with fluid mechanics. On this basis, this section recalls the relevant definitions of QSS frequency and time derivative of circulation from [4], for the developments of the paper, and provides a novel definition of RoCoF based on this theoretical background.

In the context of differential geometry, paper [3] defines geometric frequency multivector, $\hat{\Omega}_v$, as an invariant composed by a translation represented by a scalar, ρ_v , and an axial vector, ω_v , that represents a rotation:

$$\hat{\Omega}_v = \rho_v + \omega_v, \quad (1)$$

for:

$$\rho_v = \frac{|\mathbf{v} \cdot \mathbf{v}'|}{|\mathbf{v}|^2} \quad ; \quad \omega_v = \frac{\mathbf{v} \times \mathbf{v}'}{|\mathbf{v}|^2}, \quad (2)$$

where the latter term is a vector with magnitude:

$$|\omega_v| = \frac{|\mathbf{v} \times \mathbf{v}'|}{|\mathbf{v}|^2} = \kappa |\mathbf{v}|, \quad (3)$$

closely matches the instantaneous frequency obtained with a conventional PLL as concluded in [26]. The term κ is the *curvature* of the voltage trajectory. Under ideal balanced sinusoidal conditions, voltage trajectory describes an ideal circle with constant curvature and constant voltage magnitude. Consequently, $|\omega_v|$ is also constant and equal to the fundamental frequency.

In [25], an analogy between geometric frequency and Lagrange's derivative is used to decompose ω_v in different terms with precise physical meanings. These meanings come from the *fundamental theorem of the kinematics of continua* that states that an arbitrary instantaneous state of motion is at each point a uniform velocity of translation, a motion of extension, a shearing motion and a rigid rotation [27]. Among these, for the purposes of this work, the component of interest is the rigid rotation quantified by half the vorticity, $\mathbf{w}$, i.e. the curl of voltage ($\nabla \times \mathbf{v}$), as the one that captures the meaning of fundamental frequency.

Fig. 1 illustrates these findings from a geometrical point of view. The voltage trajectory describes an ellipse (black curve). In this case, the geometric frequency decomposition by means of the Lagrange's derivative expresses this ellipse as the sum of (i) a circular trajectory corresponding to the rigid motion with constant rotation at the fundamental frequency (grey curve in the Figure); and (ii) a strain component that deforms the circular trajectory into the resulting ellipse.

However, the estimation of vorticity, in this terms, requires to know the relationship between voltages and fluxes which is not possible in practice. For this reason, the work in [4] uses a Cauchy's theorem to define the QSS frequency, ω_{QSS} , as an equivalent quantity of vorticity in fluid mechanics which, for any given period T :

$$\omega_{\text{QSS}} = \frac{1}{T} \oint_T \omega_v d\tau = \frac{1}{2} \mathbf{w}, \quad (4)$$




Fig. 1. Comparison of voltage trajectories of a sinusoidal unbalanced voltage signal (black line) with respect of an ideal sinusoidal balanced voltage signal (gray line) in the $\alpha\beta\gamma$ frame.

for any given period T where the second identity is the result of Cauchy's theorem, when no torsion is assumed. The quantity ω_{QSS} thus conceptually bridges instantaneous and Fourier's frequency by retaining the slowly-varying fundamental frequency meaning while being valid not only during ideal balanced stationary conditions.

The election of period T is not trivial and is determined by the aforementioned Cauchy's theorem applicability condition. Cauchy's theorem is valid for regular curves that fulfill:

$$\kappa_T = \oint_{s_T} \kappa ds = \oint_T \kappa |v| d\tau = \oint_T |\omega_v| d\tau = 2\pi, \quad (5)$$

where κ_T and s_T are the total curvature and arc length respectively. Note that this is, in fact, the necessary condition, for a space curve, to describe a Jordan's curve, i.e. a simple closed curve [28]. Thus, we define the period as:

$$T = \inf \left\{ t : t > t_0, \int_{t_0}^{t+t_0} |\omega_v| d\tau = 2\pi \right\}. \quad (6)$$

Period, by means of (6), is defined through the voltage trajectory as the time it takes, for a given initial time t_0 , to close the described curve. Alternatively, if the trajectory does not draw a closed curve, period and, consequently, frequency cannot be defined.

In summary, estimation of QSS frequency requires to assume that the trajectory describes a Jordan curve. For this reason, [4] defines a metric, namely time derivative of circulation, Γ' , independent from condition (6), to determine whether this assumption is satisfied. Voltage trajectory describes a closed curve and, hence, QSS frequency retains the fundamental frequency value of the signal if:

$$\Gamma' = \oint_T (|v|^2)' d\tau = 0, \quad (7)$$

whereas if $\Gamma' \neq 0$, voltage trajectory is not closed and QSS frequency measurement lacks of physical meaning associated with periodicity. This condition is derived from the analog definition of circulation in fluid mechanics ($\Gamma = \oint_T |v|^2 d\tau$) and the application of Kelvin's circulation theorem.

As in practice it is not realistic to expect to obtain exactly zero from (7) due to measurement and numerical errors, we compare Γ' to a threshold, ϵ , that allows us to discriminate if the non-zero outcome comes from unavoidable practical errors or due to the loss of periodicity. Hence, at any instant t , the voltage is assumed to be periodic and ω_{QSS} to be defined if:

$$|\Gamma'| \leq \epsilon. \quad (8)$$

Then, RoCoF can be obtained as the time derivative of QSS frequency subject to condition (8):

$$\text{RoCoF} = \omega'_{\text{QSS}}, \quad \text{if } |\Gamma'| \leq \epsilon. \quad (9)$$




Fig. 2. Measurements of the normalized voltage measurements during the transformer energisation event in the $\alpha\beta\gamma$ frame.

However, in real-world applications, RoCoF calculation involving a derivative of ω_{QSS} can be prone to noise and numerical issues. For this reason, in practice, RoCoF is normally estimated as an average value of a mobile window, within a time span, Δt_w , to filter out oscillations, distortions, etc. [24]. However, such window might include “wrongly” measured frequency values such as spikes during the transient.

In this work, we propose a novel RoCoF estimation approach that derives the rate of change of QSS frequency and does not take into account the time intervals where frequency lacks physical meaning, namely, condition (8) is not satisfied. To do so, we first introduce a *tout function*, $\mathcal{T}(\Gamma')$, that substantially implements a conditional boolean value:

$$\mathcal{T}(\Gamma') = \frac{\text{sign}(\epsilon - |\Gamma'|) + 1}{2}, \quad (10)$$

that returns a 1 if condition (8) is satisfied and 0 otherwise.

We can then define the average RoCoF estimation as:

$$\overline{\text{RoCoF}} = \frac{1}{\Delta t_w} \int_{t-\Delta t_w}^t \omega'_{\text{QSS}} \mathcal{T}(\Gamma') d\tau \quad (11)$$

where $\Delta t_w = \int_{t-\Delta t_w}^t \mathcal{T}(\Gamma') d\tau$. The main feature of this RoCoF estimation approach is that periods where frequency is not defined do not contribute to the calculation of the average. Moreover, the tout function provides information of the nature of any sudden frequency variation, which can be used to adapt the average time window for a faster estimation without loss of precision.

3. Validation through measurements

In this section, expression (11) is applied to high-sampling-rate measurements in order to compare it with the conventional RoCoF computation from instantaneous frequency given by [24]:

$$\text{RoCoF} = \frac{1}{\Delta t_w} \int_{t-\Delta t_w}^t \omega'_v d\tau. \quad (12)$$

The available recordings, with a sample rate of 5kHz, were provided by the Italian TSO (Terna S.p.A.) and are related to a transformer energisation during a power system restoration test performed on a region of the Italian Transmission Network¹. The measured voltage time response related to the event is shown in Fig. 2.

Instantaneous frequency estimation, ω_v , from PLL has been filtered through a first-order Butterworth filter. Both instantaneous and QSS frequency results are shown in Fig. 3. Results show that the latter filters out the oscillations under stationary conditions while damping the spikes in the transient. This behavior is consistent with the findings in [4].

The immediate consequence of these results is that the formal estimation of the RoCoF by means of the QSS frequency in (9) is less sensitive to noise than conventional instantaneous frequency estimation, as shown in Fig. 4.

¹ Note that frequency and RoCoF relays have been disabled for the purpose of the test as the transformer energisation leads to significant RoCoF deviations during the first instants due to the small size of the network.




Fig. 3. Instantaneous frequency, ω_v , and QSS frequency, ω_{QSS} , results of the transformer energisation case study.




Fig. 4. Time derivative of instantaneous and QSS frequency, ω'_v and ω'_{QSS} respectively, of the transformer energisation case study.




Fig. 5. Overview of time derivative circulation, Γ' , results of the transformer energization case study (a), and detailed view of the results under the event (b). Periods where condition (8) is not satisfied are gray shadowed.

As previously stated, a rolling average can be applied to the formal estimation of the RoCoF and therefore, the estimation in (9) is compared to the one proposed in (11), requiring satisfying the circulation condition. With this in mind, we first assess the time derivative of circulation. We set the threshold $\epsilon = 0.05$ by considering the noise in the measurement under stationary conditions. Results show that condition (8) is not satisfied during the energization transient (see Fig. 5) and, hence, frequency (and thus RoCoF) estimation lacks of physical meaning.

By knowing the instants of satisfying the circulation condition, we finally estimate the RoCoF as an average value of a rolling window of $\Delta t_w = 500$ ms, as recommended by ENTSO-E (see [2]), for both instantaneous frequency measurement and the proposed approach in (11). Fig. 6 depicts the results. Red dashed lines represents RoCoF values of ± 1 Hz/s, namely, the minimum values considered potentially critical for the stability of the system [15].

In the first instants after the disturbance, the RoCoF computed by the instantaneous frequency exceeds the critical values, whereas the QSS-based RoCoF stays within them (as it should be in this case). Moreover, the spikes during the transient might lead to the wrong conclusion that frequency is increasing, whereas the proposed approach is capable of smoothing that response by providing a more accurate estimation of the RoCoF as the time derivative of frequency.

The inherently smoother response of the proposed approach allows us to shorten the size of the rolling time window, Δt_w , of the RoCoF estimation. Conventional estimation requires longer time windows to ensure noise and transient spikes are averaged out. Estimation by means of




Fig. 6. RoCoF estimation as an average of time derivative of instantaneous frequency (Conventional) and by definition in (11) (QSS-based) for $\Delta t_w = 500$ ms. Red-dotted line represents a realistic threshold for system stability control.




Fig. 7. Detailed view of RoCoF estimation as an average of time derivative of instantaneous frequency for $\Delta t_w = 500$ ms (Conventional) and by definition in (11) with a reduced time window, $\Delta t_w = 250$ ms (QSS-based*). Red-dotted line represents a realistic threshold for system stability control.

QSS frequency, excluding periods in which frequency and, consequently, RoCoF are not defined, permits a less restrictive methodology.

To support this conclusion, Fig. 7 plots the results of conventional RoCoF estimation for $\Delta t_w = 500$ ms and by means of (11) with 50% shorter rolling window. Results prove that, although reducing the averaging interval, the QSS based RoCoF estimation is less affected by noise and still remains within the normal operating range.

4. Applying QSS-based RoCoF to UFLS

In this Section, we present a potential application aimed to improve the RoCoF estimation of RoCoF-based protection relays in UFLS schemes. For the purpose of this study, a semi-realistic scenario is set up starting from the IEEE 39-bus benchmark system, considering the dynamics of the lines, to simulate a large outage and the subsequent activation of a two-step RoCoF-based UFLS scheme. The UFLS scheme has been implemented according to the simulation platform presented in [29], which can represent a benchmark for testing the effectiveness of RoCoF estimation in power system applications.

The IEEE 39-bus system has been modified to emulate a low-inertia system. In particular, a set of IBRs are added at every generation bus. The IBR model employed and its primary controllers are described in [30]. At generation buses, the power share of IBRs is imposed through the parameter $\gamma \in [0, 1]$, which scales the capacity of both synchronous machines and IBRs to ensure that the total generation capacity S_n remains constant:

$$S_n^{\text{IBR}} = S_n \gamma \quad ; \quad S_n^{\text{Syn}} = S_n (1 - \gamma) \quad , \quad (13)$$

where S^{IBR} and S^{Syn} refer to the apparent power delivered by IBR and synchronous resources respectively.

Inertia constants, H , power rates, S_n , and synchronous and transient reactances, x_d , x_d' , x_q , x_q' of each synchronous machine are scaled accordingly. IBR models and controllers utilized in this case study include current limiters and anti wind-up limiters. With these aforementioned assumptions, the modified 39-bus system is configured as a low-inertia system.

A two-step semi-adaptive UFLS scheme has been applied to all buses where a load is connected. Fig. 8 shows the diagram of the UFLS scheme




Fig. 8. Diagram of the UFLS scheme for each load bus k of the IEEE 39-bus modified system.




Fig. 9. Diagram of the QSS-based UFLS scheme for each load bus k of the IEEE 39-bus modified system.




Fig. 10. Tripping logic of the implemented UFLS schemes.

acting on the k^{th} -load. We assume here that a PLL computes the instantaneous frequency, ω_k , starting from the bus voltage v_k , which is then passed through a low-pass filter and a washout filter by the RoCoF block to compute RoCoF_k . The calculation of the RoCoF_k can be different if we consider the enhancement given by the derivation of Γ' — see (11) and Fig. 9.

Fig. 10 details the two tripping logic schemes implemented in the UFLS block adopted for the simulations. t_{trigger} refers to the time when a transient event occurs, t_{dw} to the time when the rolling window detects a RoCoF value exceeding a threshold and t_{trip} to the time when the protection trips.

We consider a conventional tripping logic, labeled as **UFLS**, characterized by a large rolling window, Δt_w , and a large time delay, Δt_δ , according to the recommendations given in [2,18] and the simulation performed in [29]. Then, we propose a tripping logic based on the considerations expounded in the previous sections, named **QSS UFLS**, where we are able to exclude from the rolling time window Δt_w the first instants after a trigger event where the frequency has no physical meaning associated with periodicity, until time $t_{\Gamma'}$. Since we are sure that, starting from that instant, what we are measuring is a signal with a defined period, we can afford to shorten Δt_w . In this way, the relay issuing is faster but without the risk of unintentional tripping.




Fig. 11. Tripping thresholds of the implemented UFLS schemes.




Fig. 12. CoI frequency response for different UFLS schemes with the specific parameters from Table 1.

Regarding the UFLS tripping scheme, it consists of two RoCoF thresholds, $d\omega_1$ and $d\omega_2$ which command the disconnection of two LS portions, namely ΔLS_1 and ΔLS_2 respectively. Fig. 11 shows the tripping scheme adopted for the simulations. In this specific scenario, the purely frequency thresholds are not implemented on purpose, since the aim is to analyze the effect of RoCoF measurements on the UFLS scheme and so on the dynamic performance of the system.

A large generation outage, involving both synchronous generators and IBR installed on buses 1, 2, 8, 10 is simulated, for a total of 2.44 GW of power outage. The sum of the two thresholds of all UFLS disconnects a total of 2.43 GW of load, balancing the initial outage. Parameter values utilised in the simulations are shown in Table 1.

4.1. UFLS ROCOF performance results

The results of the simulations are depicted in Fig. 12. The three curves represent the frequency of the Center of Inertia (CoI) for three different simulations:

- (i) **NO UFLS**: the UFLS is disabled.
- (ii) **UFLS**: the RoCoF-based UFLS scheme is enabled.
- (iii) **QSS UFLS**: the QSS RoCoF-based UFLS scheme is enabled.

UFLS protection scheme, effectively, improves the system response in terms of frequency stability. The QSS RoCoF-based UFLS sheds load earlier than the conventional UFLS logic. On the one hand, RoCoFs vary among the buses and on the other hand, the conventional UFLS estimation is slower and at some load buses does not exceed the thresholds due to the larger window. This behavior can be seen in Figs. 13 and 14 that show, respectively, the time derivative of frequency and average RoCoF estimations at bus 20. This case illustrates that the accuracy and speed of RoCoF estimation could be critical for UFLS after all if the conventional estimation and logic falls short.

Table 1
Data setting for the UFLS scheme of Fig. 8.

Param.	Description	UFLS	QSS UFLS
K_i	[-] PLL integral gain	0.03	0.03
K_p	[-] PLL proportional gain	0.2	0.2
T_w	[s] frequency LP filter time const.	0.01	0.01
T_r	[s] RoCoF washout filter time const.	0.01	0.01
Δt_w	[s] time window for RoCoF est.	0.5	0.25
ϵ	[pu] circulation threshold	–	0.05
$\Delta t_{\Gamma'}$	[s] Initial time span where $ \Gamma' > \epsilon$	0.0	0.023
$d\omega_1$	[pu/s] 1st UFLS threshold	0.012	0.012
$d\omega_2$	[pu/s] 2nd UFLS threshold	0.024	0.024
$\Delta t_{\delta,1}$	[s] trip delay for 1st UFLS threshold	0.2	0.2
$\Delta t_{\delta,2}$	[s] trip delay for 2nd UFLS threshold	0.2	0.2
ΔL_{S_1}	[pu] Load shed by the 1st UFLS threshold	0.2	0.2
ΔL_{S_2}	[pu] Load shed by the 2nd UFLS threshold	0.2	0.2




Fig. 13. RoCoF estimation results, at bus 20, by means of frequency time derivative for conv. and QSS UFLS schemes.




Fig. 14. RoCoF estimation results, at bus 20, by means of the average of frequency time derivative for conv. and QSS UFLS schemes. Threshold values, $d\omega_1$ and $d\omega_2$, are represented by a black line and a black dotted line respectively.

5. Remarks

5.1. On the practical implications

When estimating the RoCoF, choosing a suitable time window involves a trade-off between measurement accuracy and response promptness. Although an optimal window length may exist within this balance, UFLS devices lack knowledge of the nature of the threshold violation event. For this reason, typically prefixed conventional values are used.

By delaying the RoCoF computation, the optimal time window can be shortened. However, delaying too much can cause an insufficient or entirely absent response. Hence, the choice of a time delay is nontrivial and should not be established beforehand, as it depends on the nature of the contingency.

The proposed omission of RoCoF values that do not fulfill condition (8) right after the contingency, inherently introduces a delay that affects the UFLS response. The introduction of such delay, by means of Γ' , ensures that the RoCoF estimation is delayed properly; only non-representative values of RoCoF are omitted. Consequently, averaging time window and tripping delays can be reduced, thereby improving the protection response. Moreover, as demonstrated in Section 3, the estimation of the RoCoF by means of QSS frequency is less affected by




Fig. 15. Initial time span where condition (8) is not satisfied with respect of different threshold, ϵ , values. Range of QSS RoCoF-based UFLS optimal performance is red-shadowed.

noise than conventional estimations based on instantaneous frequency, thus enabling faster estimation without compromising accuracy.

Regarding computational feasibility, the proposed RoCoF estimation approach differs from the conventional one solely in the computation of the QSS frequency and the time derivative of circulation. We refer the interested reader to Section VII of [4]. Once these two quantities are computed, the numerical effort to estimate $\overline{\text{RoCoF}}$ is the same for both methods.

5.2. On the election of threshold ϵ

The need of defining ϵ comes from potential numerical errors and the discrete nature of the measurements. If ϵ is too restrictive (too small), the tout function, $\mathcal{T}(\Gamma')$, might continuously detect noise or estimation imperfections as transient events that lack periodicity, being the edge case equivalent, in the practical application, to not applying the UFLS protection. Conversely, if ϵ is too permissive (too large), $\mathcal{T}(\Gamma')$ might not detect such events and frequency response will be equivalent as conventional RoCoF estimation-based UFLS protection response. From this perspective, conventional UFLS schemes can be seen as a specific case of the QSS-based scheme with a, *de facto*, over-dimensioned threshold for the system requirements.

The choice of ϵ is guided by experimental observation. As shown in [4], transient events that lack periodicity represent an abrupt change of Γ' , making the discernment of events, with respect to their nature, quite evident. To support this statement we plot, in Fig. 15, the initial time delay, $\Delta t_{\Gamma'}$, with respect of different ϵ values, of the practical application case study.

Within the edge cases, the vast majority of the range of possible ϵ values falls in a plateau where the delay, $\Delta t_{\Gamma'}$, does not change. Following the findings in [4], the ϵ value, of a specific model, should be chosen only based on the sampling time of the discrete data. From the experience obtained from real-world data, we recommend to evaluate ϵ according to the following approach: (i) using historical data, evaluate Γ' under stationary conditions to assess the impact of noise and

numerical errors; and (ii) set a conservative (over-dimensioned) value of ϵ according to the results obtained in stationary conditions.

6. Conclusions

This paper discusses theoretical and experimental limitations of the RoCoF computation and proposes a novel definition of RoCoF, which is more compliant with the challenges issued by the actual structure of the power system. Thanks to the definition of the QSS frequency and the time derivative of the circulation, the time intervals where the frequency has no physical meaning are excluded from the moving average of the classical RoCoF computation.

This definition shows a significant improvement in the RoCoF estimation when applied to real-world measurement, helping to avoid possible unintentional tripping of RoCoF-based relays during highly-distorted transient events. Moreover, if applied to a RoCoF-based UFLS scheme, robust frequency estimation, by means of ω_{QSS} , and information from Γ' can be used to adapt and shorten the typical rolling window and time delay before the issuing of the relay, speeding up the frequency restoration and decreasing the absolute value of the frequency nadir.

CRediT authorship contribution statement

J. Gutiérrez-Florensa: Writing – original draft, Methodology, Investigation, Formal analysis; **F. Sanniti:** Writing – original draft, Methodology, Investigation, Formal analysis; **D. Tedeschi:** Resources; **L. Sigris:** Writing – review & editing, Supervision; **Á. Ortega:** Writing – review & editing, Supervision; **F. Milano:** Writing – review & editing, Supervision, Formal analysis.

Funding

This work is supported by the [Science Foundation Ireland](#) (SFI) by funding J. Gutierrez-Florensa and F. Milano under NexSys project, Grant No. [21/SPP/3756](#).

Declaration of competing interest

The authors declare the following financial interests/personal relationships which may be considered as potential competing interests:

Federico Milano reports financial support was provided by Taighde Éireann Research Ireland. If there are other authors, they declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Data availability

The data that has been used is confidential.

References

- [1] IEEE/IEC international standard - measuring relays and protection equipment - Part 118-1: synchrophasor for power systems - Measurements, 2018.
- [2] ENTSO-E, Rate of change of frequency (RoCoF) withstand capability, ENTSO-E guidance document for national implementation for network codes on grid connection, Technical Report, Brussels, Belgium, 2018.
- [3] F. Milano, A geometrical interpretation of frequency, *IEEE Trans. Power Syst.* 37 (1) (2022) 816–819. <https://doi.org/10.1109/TPWRS.2021.3108915>
- [4] J. Gutiérrez-Florensa, Á. Ortega, L. Sigris, F. Milano, Quasi steady-state frequency, *IEEE Trans. Circuits Syst.* 172 (2025) 2986–2998.
- [5] A. Riepnies, H. Kirkham, Rate of change of frequency measurement, in: Int. Scientific Conference on Power and Electrical Engineering of Riga Technical University (RTUCON), 2016, pp. 1–5. <https://doi.org/10.1109/RTUCON.2016.7763110>
- [6] X. Deng, et al., Review of RoCoF estimation techniques for low-inertia power systems, *Energies* 16 (9) (2023). <https://doi.org/10.3390/en16093708>
- [7] R. Ferrero, P.A. Pegoraro, S. Toscani, Proposals and analysis of space vector-based phase-locked-loop techniques for synchrophasor, frequency, and ROCOF measurements, *IEEE Trans. Instr. Meas.* 69 (5) (2020) 2345–2354. <https://doi.org/10.1109/TIM.2020.2973873>
- [8] M. Bertocco, et al., Compressive sensing of a Taylor-Fourier multifrequency model for synchrophasor estimation, *IEEE Trans. Instr. Meas.* 64 (12) (2015) 3274–3283. <https://doi.org/10.1109/TIM.2015.2450295>
- [9] A.K. Singh, B.C. Pal, Rate of change of frequency estimation for power systems using interpolated DFT and Kalman filter, *IEEE Trans. Power Syst.* 34 (4) (2019) 2509–2517. <https://doi.org/10.1109/TPWRS.2018.2881151>
- [10] P.S. Wright, et al., Field measurement of frequency and ROCOF in the presence of phase steps, *IEEE Trans. Instr. Meas.* 68 (6) (2019) 1688–1695. <https://doi.org/10.1109/TIM.2018.2882907>
- [11] Y. Zuo, G. Frigo, A. Derviškić, M. Paolone, Impact of synchrophasor estimation algorithms in ROCOF-based under-frequency load-shedding, *IEEE Trans. Power Syst.* 35 (2) (2020) 1305–1316. <https://doi.org/10.1109/TPWRS.2019.2936277>
- [12] G. Rietveld, P.S. Wright, A.J. Roscoe, Reliable rate-of-change-of-frequency measurements: use cases and test conditions, *IEEE Trans. Instr. Meas.* 69 (9) (2020) 6657–6666. <https://doi.org/10.1109/TIM.2020.2986069>
- [13] G. Frigo, A. Derviškić, Y. Zuo, M. Paolone, PMU-based ROCOF measurements: uncertainty limits and metrological significance in power system applications, *IEEE Trans. Instr. Meas.* 68 (10) (2019) 3810–3822. <https://doi.org/10.1109/TIM.2019.2907756>
- [14] IEEE standard for synchrophasor measurements for power systems – amendment 1: modification of selected performance requirements, 2014, <https://doi.org/10.1109/IEEESTD.2014.6804630>
- [15] ENTSO-E RG-CE System Protection & Dynamics Sub Group, Frequency stability evaluation criteria for the synchronous zone of continental Europe, Technical Report, Brussels, Belgium, 2016.
- [16] P. Gupta, R.S. Bhatia, D.K. Jain, Active ROCOF relay for islanding detection, *IEEE Trans. Power Del.* 32 (1) (2017) 420–429. <https://doi.org/10.1109/TPWRD.2016.2540723>
- [17] D.M. Lavery, R.J. Best, D.J. Morrow, Loss-of-mains protection system by application of phasor measurement unit technology with experimentally assessed threshold settings, *IET Gener. Transm. Distrib.* 9 (2) (2015) 146–153. <https://doi.org/10.1049/iet-gtd.2014.0106>
- [18] D.S. Protection, ENTSO-E System and Group, Technical Background and Recommendations for Defence Plans in the Continental Europe Synchronous Area, Technical Report, Brussels, Belgium, 2010.
- [19] M. Sun, G. Liu, M. Popov, V. Terzija, S. Azizi, Underfrequency load shedding using locally estimated RoCoF of the center of inertia, *IEEE Trans. Power Syst.* 36 (5) (2021) 4212–4222. <https://doi.org/10.1109/TPWRS.2021.3061914>
- [20] P. Kundur, et al., Power system stability, *Power Syst. Stab. Control* 10 (1) (2007) 623–626.
- [21] ENTSO-E, 28 April blackout, 2025, <https://www.entsoe.eu/publications/blackout/28-april-2025-iberian-blackout/>.
- [22] G. Lemos, A. Melgar, M. Torres, M. Rios, State of emergency declared after blackout plunges most of Chile into darkness, ? edition.cnn.com/2025/02/25/america/chile-blackout-14-regions-intl-latam.
- [23] U. Rudez, R. Mihalic, WAMS-based underfrequency load shedding with short-term frequency prediction, *IEEE Trans. Power Del.* 31 (4) (2016) 1912–1920. <https://doi.org/10.1109/TPWRD.2015.2503734>
- [24] ENTSO-E, Inertia and rate of change of frequency (RoCoF), Technical Report v17, ENTSO-E, Brussels, Belgium, 2020.
- [25] F. Milano, Equivalence between geometric frequency and lagrange derivative, *IEEE Trans. Circuits Syst.* 172 (9) (2025) 4800–4809. <https://doi.org/10.1109/TCSI.2024.3490394>
- [26] F. Milano, et al., Using differential geometry to revisit the paradoxes of the instantaneous frequency, *IEEE Open Access J. Power Energy* 9 (2022) 501–513.
- [27] C. Truesdell, *The Kinematics of Vorticity*, Indiana University Press, Indiana, US, Indiana, US, 1954.
- [28] J.J. Stoker, *Differential Geometry*, John Wiley & Sons, Ltd, 1969.
- [29] A. Derviškić, Y. Zuo, G. Frigo, M. Paolone, Under frequency load shedding based on PMU estimates of frequency and ROCOF, in: IEEE ISGT-Europe, 2018, pp. 1–6. <https://doi.org/10.1109/ISGTEurope.2018.8571481>
- [30] G. Tzounas, F. Milano, Improving the frequency response of DERs through voltage feedback, in: IEEE PES General Meeting, 2021, pp. 1–5. <https://doi.org/10.1109/PESGM46819.2021.9638236>