

Evaluation of Automatic Generation Control (AGC) regulators by performance indices using data from real operation

F. Fernández Bernal; I. Egido Cortés; L. Rouco Rodríguez

Abstract-

Indices to evaluate AGC performance under both simulation and real operation are presented. These indices are based on functional dependence and statistical analysis avoiding large and long periods of data collection necessary for comparison of different regulators in real operation. A method to perform the global evaluation of the regulator using the individual values obtained for the indices is also presented. Variables typically measured in power systems are used to compute the indices. Examples of calculated values of the indices using data from real operation of two regulators in the same area of the Spanish power system are presented. Response criterion imposed in the Spanish power system is used.

Index Terms-

Due to copyright restriction we cannot distribute this content on the web. However, clicking on the next link, authors will be able to distribute to you the full version of the paper:

[Request full paper to the authors](#)

If you institution has a electronic subscription to IET Generation Transmission & Distribution, you can download the paper from the journal website:

[Access to the Journal website](#)

Citation:

Egido, I.; Fernández-Bernal, F.; Rouco, L. "Evaluation of Automatic Generation Control (AGC) regulators by performance indices using data from real operation", IET Generation Transmission & Distribution, vol.1, no.2, pp.294-302, March, 2007.