

Total least squares and discrete time line models in HV distance protection

F.L. Pagola y de las Heras; C. Fernández Martínez

Abstract-

This paper discusses the applicability of the parameter estimation procedure known as Total Least Squares, to the distance protection of high voltage transmission lines. The TLS based algorithm presented in the paper uses a two parameter discrete-time model for the line to be protected. The procedure is able to provide precise results (within specifications) in shorter time than other well known procedures, showing an improved dependability/security compromise. Two algorithms designed for different power line conditions, provide the procedure with adaptive behavior Trip orders are provided in minimum time, according to the noise level in the current and voltage signals.

Index Terms-

Due to copyright restriction we cannot distribute this content on the web. However, clicking on the next link, authors will be able to distribute to you the full version of the paper:

[Request full paper to the authors](#)

If your institution has an electronic subscription to IEEE Transactions on Power Delivery, you can download the paper from the journal website:

[Access to the Journal website](#)

Citation:

Pagola, F.L.; Fernández, C. "Total least squares and discrete time line models in HV distance protection", IEEE Transactions on Power Delivery, vol.14, no.1, pp.74-79, January, 1999.